

PHONE: 512-778-5449

**REPORT**  
**CONSUMER CONFIDENCE**  
**2015**

**CITY OF LIBERTY HILL**  
**WATER SYSTEM**

# Annual Drinking Water Quality Report

TX2460013

CITY OF LIBERTY HILL

Annual Water Quality Report for the period of January 1 to December 31, 2015

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report contact:

Name Donalda Wayne Bonnet

Phone (512) 745-7060

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (512)778-5449

CITY OF LIBERTY HILL is Ground Water

## Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

**Information about Source Water Assessments**

TCEQ completed an assessment of your source water and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact 512.778.5449.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL: <http://gis3.tceq.state.tx.us/swav/Controller/index.jsp?wfsrc=>

Further details about sources and source-water assessments are available in Drinking Water Watch at the following URL: <http://dww.tceq.texas.gov/DWW>

Source Water Name	Type of Water	Report Status	Location
1 - 102 GROVE ST	GW	Y	_____
2 - 501 LOOP 332	GW	Y	_____
3 - 12235 W HWY 29	GW	Y	_____
4 - 851 STUBBLEFIELD LN	GW	Y	_____
5 - 4140 RR 1869	GW	Y	_____
6 - SH 29 / STONEWALL PKWY	GW	_____	_____
7 - 202 MYRTLE	GW	_____	_____
GW FROM CHISHOLM TRAIL SUD	GW	_____	_____
			CC FROM TX2460043

**2015 Regulated Contaminants Detected**

**Lead and Copper**

**Definitions:**

**Action Level Goal (ALG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.  
**Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	09/15/2013	1.3	1.3	0.131	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	09/15/2013	0	15	2.69	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

**Water Quality Test Results**

**Definitions:**

**Avg:** The following tables contain scientific terms and measures, some of which may require explanation.

**Maximum Contaminant Level or MCL:** Regulatory compliance with some MCLs are based on running annual average of monthly samples.

**Maximum Contaminant Level Goal or MCLG:** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum residual disinfectant level or MRDL:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum residual disinfectant level goal or MRDLG:** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**MFL:** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**na:** million fibers per liter (a measure of asbestos)

**NTU:** not applicable.

**PCU/L:** nephelometric turbidity units (a measure of turbidity)

**picCi/L:** picocuries per liter (a measure of radioactivity)

## Water Quality Test Results

ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
ppt:	parts per trillion, or nanograms per liter (ng/L)
ppq:	parts per quadrillion, or picograms per liter (pg/L)

**Regulated Contaminants**

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Halacetic Acids (THAA5)*	2015	1	0 - 1.2	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTTHM)	2015	2	0 - 3.3	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	2015	2.6	0 - 2.6	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	2015	0.15	0.071 - 0.15	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2015	0.75	0.7 - 0.75	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2015	0.15	0.03 - 0.15	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks; sewage; Erosion of natural deposits.
Nitrite [measured as Nitrogen]	2015	0.01	0 - 0.01	1	1	ppm	N	Runoff from fertilizer use; Leaching from septic tanks; sewage; Erosion of natural deposits.
Selenium	2015	9.4	4.6 - 9.4	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta photon emitters	2015	18.5	15.7 - 18.5	0	50	pCi/L*	N	Decay of natural and man-made deposits.
Combined Radium 226/228	2015	5	3.8 - 5	0	5	pCi/L	N	Erosion of natural deposits.

\*EPA considers 50 pCi/L to be the level of concern for beta particles.

Gross alpha excluding radon and uranium	2015	9	5.5 - 10.1	0	15	pci/L	N	Erosion of natural deposits.
Volatiles Organic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Xylenes	2015	0.0007	0 - 0.0007	10	10	ppm	N	Discharge from petroleum factories; Discharge from chemical factories.

Disinfectant	Year	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Violation Y/N	Likely source of Contamination
Chlorine	2015	1.52	.37	3.12	4.0	4.0	ppm	N	Water additive used to control microbes

**Violations Table**

**Lead and Copper Rule**

The Lead and Copper Rule protects public health by minimizing lead and copper levels in drinking water, primarily by reducing water corrosivity. Lead and copper enter drinking water mainly from corrosion of lead and copper containing plumbing materials.

Violation Type	Violation Begin	Violation End	Violation Explanation
FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/01/2010	2015	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.